

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.: 7270-0999:111

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Alarm Industry Products, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: David Mazur (203) 699-3000

DESIGN: Models AI281B, AI282B combination fixed temperature/rate-of-rise heat detectors; Models AI283B, AI284B fixed temperature heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: AI281B, AI283B:135°F

AI282B, AI284B:194°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, Alarm Industry Products (AIP), model number, temperature, electrical ratings and UL label.

APPROVAL: Listed as fixed temperature and/or combination fixed temperature/rate-of-rise heat detectors for use with separately listed compatible bases and fire alarm control units.

***XLF:** 7270-1388:113

*Corrected 07-17-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 30, 2001**

Listing Expires **June 30, 2002**

Authorized By: **BEN HO**, Supervising Deputy
Program Manager